



# DANGEROUS GOODS SAFETY REGULATION OF LP GAS STORAGE

Do you store LP Gas...



Cylinders in a quantity of less than 120 litres (maximum size 36 litres) at a residence or 432 litres (maximum size 108 litres) at a factory or workshop?

YES

**MINOR STORAGE**  
Comply with Section 2 of AS 1596



Cylinders in a quantity less than 500 litres at a commercial site?

YES

**SMALL QUANTITY DANGEROUS GOODS LOCATION**  
Comply with DG storage regulations [rr. 123 - 133]; see AS 1596 for guidance



In a quantity between 500 litres and 5,000 litres at a commercial site?

YES

**PLACARDING QUANTITY**  
DG storage regulations apply; apply risk assessment and risk control measures



In a quantity exceeding 5,000 litres at a commercial site?

YES

**MANIFEST QUANTITY**  
DG storage regulations apply; DG Site Licence required; apply risk assessment and risk control measures